



# PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

***EMIRAK Multi Gas Analyser  
NO/NOx (Hot Wet & Cold Dry), CO, O<sub>2</sub> (Dry & Wet) & SO<sub>2</sub>***

manufactured by:

**Signal Group Ltd**  
*Ambitech Division  
Regal Way  
Faringdon  
Oxon SN7 7BX  
England*

has been assessed by Sira Certification Service  
and for the conditions stated on this certificate complies with:

**MCERTS Performance Standards for Continuous Emission  
Monitoring Systems, Version 2.1 dated April 2003  
& the performance criteria specified in Version 3.1 dated July 2008 (EN 15267-3: 2007)\*  
& QAL 1 as defined in EN 14181: 2004**

### Certification Ranges :

NO/NOx (wet) & (dry)	0 – 50	to	0 – 200	ppm	(0 – 67 mg/m <sup>3</sup> to 0 to 268 mg/m <sup>3</sup> )
CO	0 – 100	to	0 – 1000	ppm	(0 – 125 mg/m <sup>3</sup> to 0 to 1250 mg/m <sup>3</sup> )
SO <sub>2</sub>	0 – 50	to	0 – 425	ppm	(0 – 143 mg/m <sup>3</sup> to 0 to 1215 mg/m <sup>3</sup> )
SO <sub>2</sub>	0 – 85	to	0 – 425	ppm	(0 – 243 mg/m <sup>3</sup> to 0 to 1215 mg/m <sup>3</sup> )
O <sub>2</sub> (wet) & (dry)	0 - 25	%Vol			

\* Laboratory and field tests conducted on one instrument.

Project No: 674/0187 & 674/0394  
Certificate No: Sira MC090141/05  
Initial Certification: 17 March 2009  
This Certificate Issued: 12 February 2012  
Renewal Date: 16 March 2014

Technical Director

*MCERTS is operated on behalf of the Environment Agency by*

## **Sira Certification Service**

12 Acorn Industrial Park, Crayford Road, Crayford  
Dartford, Kent, UK, DA1 4AL

Tel: 01322 520500 Fax: 01322 520501

*This certificate may only be reproduced in its entirety and without change*



## Approved Site Application

Any potential user should ensure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency Monitoring Technical Guidance Notes available at [www.mcerts.net](http://www.mcerts.net)

On the basis of the assessment and the ranges required for compliance with EU Directives this instrument is considered suitable for use on Gas Turbine large combustion plant applications. This CEM has been proven suitable for its measuring task (parameter and composition of the flue gas) by use of the QAL 1 procedure specified in EN14181, for LCPD for the ranges specified. The lowest certified range for each determinand shall not be more than 2.5X the ELV for LCPD and other types of application.

## Field Trial

The Emirak measuring system was installed for 3 months on a gas turbine application.

## Basis of Certification

This certification is based on the following Test Report(s) and on Sira's assessment and ongoing surveillance of the product and the manufacturing process:

Laboratory Test Report:	Report PED0193RevC, dated 03/03/2009
Field Test Report:	PB Power 63412A-0001, dated February 2009
Sira Report:	Report No. 06-2, dated 03/03/2009
Laboratory Test Report:	Report PED0224 Rev C, dated 15/04/2009
Sira Report:	Report No. 07-01, dated 16/04/2009
Laboratory Test Report:	Report PED0268 Rev C, dated 16/11/2009
Sira Report:	Report No. 08-01, dated 17/11/2009

## Product Certified

The Emirak measuring system consists of the following parts:

- Sampling Probe M&C SP2000H
- Signal Heated Line 20m
- Sample Conditioning System based on a refrigerative chiller
- Air Conditioned Enclosure
- NOx converter (for SO<sub>2</sub> 0-50ppm range option)

This certificate applies to all instruments fitted with software version V4.4 and V6.0 (serial number SP02742-005 onwards).

Certificate No: Sira MC090141/05  
This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



**Certified Performance**

Laboratory and field tests were conducted in accordance with the requirements of EN 15267-3: 2007 on one Emirak System Model SP02742-EMI, serial No. SP02742-005. Additional laboratory tests were conducted in accordance with the requirements of EN 15267-3: 2007 to include the NOx (cold, dry) analysis option on one Emirak system containing NOx analyser module serial No.WM08773-000.

Further laboratory tests were conducted in accordance with the requirements of EN 15267-3: 2007 to include SO<sub>2</sub> (0 to 50 ppm) analysis option on one Emirak system containing the SO<sub>2</sub> analyser module serial No. WM08918-001.

The instrument was evaluated for use under the following conditions:

- Ambient Temperature Range: 18°C-26°C (see note below)
- Enclosure IP rating: IP65

Note: If the instrument is supplied with an enclosure then the ambient temperature shall be monitored inside the enclosure to ensure that it stays within the above ambient temperature range.

Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Response time						
CO					45s	<200s
NOx (Wet)					19s	<200s
NO (Wet)					17s	<200s
NOx (Dry)					27s	<200s
NO (Dry)					24s	<200s
SO <sub>2</sub> (0 to 85ppm)					70s	<200s
SO <sub>2</sub> (0 to 50 ppm)					60s	<200s
O <sub>2</sub> (Dry)					39s	<200s
O <sub>2</sub> (Wet)					27s	<200s

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Repeatability standard deviation at zero point						<2%
CO	0.12					<2%
NOx (Wet)	0.03					<2%
NO (Wet)	0.03					<2%
SO <sub>2</sub> (0 to 85ppm)	0.04					<2%
SO <sub>2</sub> (0 to 50ppm)	0.03					<2%
O <sub>2</sub> (Dry)	0.01					<0.2%
O <sub>2</sub> (Wet)	0.00					<0.2%
Repeatability standard deviation at span point						
CO	0.08					<2.0%
NOx (Wet)	0.44					<2.0%
NO (Wet)	0.41					<2.0%
NOx (Dry)	0.08					<2.0%
NO (Dry)	0.10					<2.0%
SO <sub>2</sub> (0 to 85ppm)	0.38					<2.0%
SO <sub>2</sub> (0 to 50ppm)	0.11					<2.0%
O <sub>2</sub> (Dry)	0.08					<0.2%
O <sub>2</sub> (Wet)	0.05					<0.2%
Lack-of-fit						
CO		-0.79				<2.0%
NOx (Wet)		-0.69				<2.0%
NO (Wet)		-0.72				<2.0%
SO <sub>2</sub> (0 to 85ppm)	-0.28					<2.0%
SO <sub>2</sub> (0 to 50ppm)	0.25					<2.0%
O <sub>2</sub> (Dry)	0.10					<0.2%
O <sub>2</sub> (Wet)	0.15					<0.2%
Influence of ambient temperature zero point						
CO			-1.76	-3.10		<5.0%
NOx (Wet)			-1.81			<5.0%
NO (Wet)						<5.0%

Certificate No: Sira MC090141/05  
This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
SO <sub>2</sub> (0 to 85ppm)	0.29					<5.0%
SO <sub>2</sub> (0 to 50ppm)	0.12					<0.5%
O <sub>2</sub> (Dry)	-0.16					<0.5%
O <sub>2</sub> (Wet)	-0.38					
Influence of ambient temperature span point						
CO	0.00					<5.0%
NO <sub>x</sub> (Wet)				-3.80		<5.0%
NO (Wet)				-3.50		<5.0%
SO <sub>2</sub> (0 to 85ppm)				-2.10		<5.0%
SO <sub>2</sub> (0 to 50ppm)	0.19					<5.0%
O <sub>2</sub> (Dry)	-0.40					<0.5%
O <sub>2</sub> (Wet)	-0.35					<0.5%
Influence of sample gas flow for extractive						
CO	0.45					<2.0%
NO <sub>x</sub> (Wet)		-0.89				<2.0%
NO (Wet)		0.98				<2.0%
SO <sub>2</sub> (0 to 85ppm)		0.54				<2.0%
SO <sub>2</sub> (0 to 50ppm)	-0.10					<2.0%
O <sub>2</sub> (Dry)	-0.09					<0.2%
O <sub>2</sub> (Wet)	-0.16					<0.2%

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Influence of voltage variations 190 to 250V						
CO	0.27					<2.0%
NOx (Wet)			1.56			<2.0%
NO (Wet)			1.45			<2.0%
SO <sub>2</sub> (0 to 85ppm)	-0.21					<2.0%
SO <sub>2</sub> (0 to 50ppm)	0.40					<2.0%
O <sub>2</sub> (Dry)	0.04					<0.2%
O <sub>2</sub> (Wet)	0.06					<0.2%
Cross-sensitivity at zero with interferents						
CO		-0.54				<4.0%
NOx (Wet)			1.50			<4.0%
NO (Wet)			1.30			<4.0%
NOx (Dry)		0.70				<4.0%
NO (Dry)		0.60			Note 1	<4.0%
SO <sub>2</sub> (0 to 85ppm)				-3.82		<4.0%
SO <sub>2</sub> (0 to 50ppm)			1.96			<4.0%
O <sub>2</sub> (Dry)	0.00					<0.4%
O <sub>2</sub> (Wet)	0.00					<0.4%

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Cross-sensitivity at span with interferents					Note 1	
CO						
NOx (Wet)			-1.24			
NO (Wet)		-0.75				
NOx (Dry)	0.00					
NO (Dry)	-0.75					
SO <sub>2</sub> (0 to 85ppm)	0.00					<4.0%
SO <sub>2</sub> (0 to 50ppm)				2.38		<4.0%
O <sub>2</sub> (Dry)				2.03		<4.0%
O <sub>2</sub> (Wet)	0.00					<4.0%
	0.00				<0.4%	
					<0.4%	
Converter Efficiency (Wet)					97.3%	>95%
Converter Efficiency (Dry)					96.3%	>95%

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Measurement uncertainty						Guidance – at least 25% below max permissible uncertainty
CO (100 ppm)					4.27 mg/Nm <sup>3</sup>	
CO (1000 ppm)					30.3 mg/Nm <sup>3</sup>	
NO <sub>x</sub> (50 ppm) (Wet)					6.57 mg/Nm <sup>3</sup>	
NO <sub>x</sub> (200 ppm) (Wet)					24.6 mg/Nm <sup>3</sup>	
NO (50 ppm) (Wet)					3.91 mg/Nm <sup>3</sup>	
NO(200 ppm) (Wet)					24.6 mg/Nm <sup>3</sup>	
NO <sub>x</sub> (50 ppm) (Dry)					6.27 mg/Nm <sup>3</sup>	
NO <sub>x</sub> (200 ppm) (Dry)					24.8 mg/Nm <sup>3</sup>	
NO (50 ppm) (Dry)					3.78 mg/Nm <sup>3</sup>	
NO(200 ppm) (Dry)					14.9 mg/Nm <sup>3</sup>	
SO <sub>2</sub> (50ppm)					5.27 mg/Nm <sup>3</sup>	
SO <sub>2</sub> (85 ppm)					13.7 mg/Nm <sup>3</sup>	
SO <sub>2</sub> (425 ppm)					41.2 mg/Nm <sup>3</sup>	
O <sub>2</sub> (dry)					0.74%vol	
O <sub>2</sub> (Wet)					0.68%vol	

Note 1: Cross-sensitivity test has been conducted with the following interferents:  
 O<sub>2</sub>, H<sub>2</sub>O, CO, CO<sub>2</sub>, CH<sub>4</sub>, NO, NO<sub>2</sub>, SO<sub>2</sub>. Not tested with interferents N<sub>2</sub>O, NH<sub>3</sub> and HCl.

Cross-sensitivity test data was recalculated for NO<sub>x</sub>/NO (dry) from the original test data with the interferent H<sub>2</sub>O vapour removed.

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*





Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Calibration function (field)						
CO					0.98	>0.90
NO <sub>x</sub> (Wet)					0.99	>0.90
NO (Wet)					0.99	>0.90
SO <sub>2</sub>					0.97	>0.90
O <sub>2</sub> (Dry)					0.99	>0.90
O <sub>2</sub> (wet)					0.99	>0.90
Response time (field)						
CO					42s	<200s
NO <sub>x</sub> (Wet)					22s	<200s
NO (Wet)					23s	<200s
SO <sub>2</sub>					103s	<200s
O <sub>2</sub> (Dry)					42s	<200s
O <sub>2</sub> (Wet)					28s	<200s
Lack of fit (field)						
CO		-0.79				<2.0%
NO <sub>x</sub> (Wet)			1.38			<2.0%
NO (Wet)		-0.93				<2.0%
SO <sub>2</sub>			-1.07			<2.0%
O <sub>2</sub> (Dry)	0.03					<0.2%
O <sub>2</sub> (Wet)	-0.14					<0.2%
Maintenance interval					>8 days	>8 days

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Zero and Span drift requirement	The system performs an automatic calibration daily at a preset time. Performing a $y=mx+c$ correction to the data.					Clause 6.13 & 10.13  Manufacturer shall provide a description of the technique to determine and compensate for zero and span drift.
Change in zero point over maintenance interval			1.65			<3%
CO						<3%
NOx (Wet)		0.46				<3%
NO (Wet)	0.39					<3%
SO <sub>2</sub>		0.75				<3%
O <sub>2</sub> (Dry)	0.05					<0.2%
O <sub>2</sub> (Wet)	0.00					<0.2%
Change in span point over maintenance interval						<3%
CO	0.32					<3%
NOx (Wet)				2.64		<3%
NO (Wet)				2.39		<3%
SO <sub>2</sub>	0.47					<3%
O <sub>2</sub> (Dry)	0.09					<0.2%
O <sub>2</sub> (Wet)	0.06					<0.2%
Availability					98.2%	>95%
					98.2%	(>98% for O <sub>2</sub> )
<b>Reproducibility</b> It was impractical due to size constraints to conduct parallel tests of the AMS. Therefore it was not possible to calculate the reproducibility.						

Certificate No: Sira MC090141/05  
 This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*



## Description:

The Emirak multi gas analyser uses the following measuring principles:

- NO/NO<sub>2</sub>/NO<sub>x</sub> Wet Hot Chemiluminescent analyser with partial vacuum
- NO/NO<sub>2</sub>/NO<sub>x</sub> Dry Cold Chemiluminescent analyser with partial vacuum
- O<sub>2</sub> Hot Wet Zirconia analyser
- O<sub>2</sub> Dry Paramagnetic analyser
- H<sub>2</sub>O calculated from Hot Wet O<sub>2</sub> and Dry O<sub>2</sub> measurements
- CO Dry Gas Filter Correlation (GFC) analyser operating on the infrared principle.
- SO<sub>2</sub> Dry Non-Dispersive analyser operating on the infrared principle.
- SO<sub>2</sub> Dry Non-Dispersive analyser operating on the infrared principle (requires NO<sub>x</sub> converter for 0-50ppm range)

The gaseous components of the emissions are monitored using extractive sampling which is achieved by continuously transporting a gas sample from the stack to the CEMS mounted in the equipment shelter. The power and the signals for the probe are controlled via the CEMS equipment within the shelter. The CEMS system is an integrated computer controlled gas analysis and data logging system. The data from the Emirak is collected by a Data Acquisition and Data Handling System (DAHS) computer which is located in the Turbine control room. The DAHS computer generates the emission compliance report to the regulating authority.

## General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of Sira Certificates'. The design of the product certified is defined in the Sira Design Schedule for certificate No. Sira MC090141/04.
2. If certified product is found not to comply, Sira Certification Service should be notified immediately at the address shown on this certificate.
3. The Certification Marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of Sira Certificates'.
4. This document remains the property of Sira and shall be returned when requested by the company.

Certificate No: Sira MC090141/05  
This Certificate Issued: 12 February 2012

*This certificate may only be reproduced in its entirety and without change*