

PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

NivuFlow 750 Echo Profile Flowmeter and POA-R sensor

Manufactured by:

NIVUS GmbH

Im Täle 2
75031 Eppingen
Germany

has been assessed by Sira Certification Service
And for the conditions stated on this certificate complies with:

MCERTS Performance Standards for Continuous Water Monitoring Equipment, Version 2.4 dated February 2013

The combined performance characteristic (U_c , the expanded uncertainty) is **2.16%** (Class2)

Certification Ranges:

Full Pipe Applications

Velocity	0.1 m/s to 3 m/s
Pipe size	DN150, DN300 and DN500

Project No.:	70046569
Certificate No:	Sira MC170320/01
Initial Certification:	14 February 2017
This Certificate issued:	17 March 2021
Renewal Date:	14 February 2022



Andrew Young
Environmental Project Engineer

MCERTS is operated on behalf of the Environment Agency by

Sira Certification Service

Unit 6, Hawarden Industrial Park
Hawarden, Deeside, CH5 3US
Tel: +44 (0)1244 670 900



0011

sira
CERTIFICATION

*The MCERTS certificate consists of this document in its entirety.
For conditions of use, please consider all the information within.
This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certificate Contents

Approved Site Application.....	2
Basis of Certification	2
Product Certified.....	2
Certified Performance	3
Description.....	5
General Notes	5

Approved Site Application

Any potential user should ensure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency Monitoring Technical Guidance Notes available at www.mcerts.net

The product is suitable for use, where it is appropriate, for regulated applications such as abstraction, effluent discharge, ultraviolet disinfection and industrial processing.

Basis of Certification

This certification is based on the following Test Report(s) and on Sira's assessment and ongoing surveillance of the product and the manufacturing process:

- Nivus GmbH Test Report - Test report NivuFlow 750 with POA pipe Sensor and air ultrasound level meter, dated 08/12/2016
- Sira Witness Test Report (incorporated with Evaluation Report) dated 08/07/2016

Product Certified

The measuring system consists of the following parts:

- A standard version transmitter NF 750 (NF7-5S1 W0/2 A/D 001)
- A multiple version transmitter NF 750 (NF7-5M3 W0/4 A/D 001)
- A V sensor POA pipe with POA-V200RT010L0, POA-V2D0RT010K0, POA-V200RTE10L0, POA-V2D0RTE10K0)

Each system should be minimum composed of one transmitter, one velocity sensor.

This certificate applies to all instruments fitted with software version 1.23 (Transmitters NF750), 2.06 (Sensor POA).

Certificate No: Sira MC170320/01
This Certificate issued: 17 March 2021

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certified Performance

The instrument was evaluated for use under the following conditions:

Ambient Temperature Range: -20°C to +50°C

The instrument meets MCERTS Class 2 requirements for the combined performance characteristic as specified in Table 6 of the MCERTS performance standard and for the tests carried out on 150 mm, 300 mm and 500 mm conduits. Details of individual performance characteristics are summarised below:

Results are expressed as error % of certification range, unless otherwise stated.

Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Mean Error			1.52			±4% (Class 2)
Repeatability		0.61				1% (Class 1)
Supply Voltage (93 to 232 VAC, 10 to 35 VDC)	0.16					0.5% (Class 1)
Output Impedance (73 Ω to 478 Ω)	0.02					0.5% (Class 1)
Fluid Temperature (+5°C to +30°C)	0.28					0.5% (Class 1)
Ambient Air Temperature (-20°C to +50°C)	0.20					0.5% (Class 1)
Relative Humidity (95%RH)	0.18					0.5% (Class 1)
Bi-Directional Flow		0.73				1.5% (Class 1)
Effect of conduit size						Clause 6.3.17 ±4% Class 2
DN150 m/s						
0.17			1.31			
0.40		0.74				
0.70	0.23					
1.05		0.92				
1.40			-1.61			
1.90			1.46			
2.20	0.08					
2.50	-0.38					
2.80			-1.20			

Certificate No: Sira MC170320/01
This Certificate issued: 17 March 2021

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Effect of Conduit Size						
DN300 m/s						Clause 6.3.17
0.1			-1.26			±4% Class 2
0.15			-1.54			
0.45		0.87				
0.75	0.27					
1.05			-1.17			
1.55		-0.73				
1.95	-0.25					
2.25	-0.26					
DN500 m/s						Clause 6.3.17
0.15	-0.13					±1.5% Class 1
0.45	-0.10					
0.75			-1.06			
Response time					29 seconds	<30 seconds
Combined Performance Characteristic					2.16%	Clause 4.2.1 Class 2 (≤5%)
Warm Up Time					39 seconds	Clause 6.1.2 To be reported
Error under field test conditions	Max error 7.61% Min error -4.23% Mean error 3.40% Proportion of errors $\leq 5\%$ = 79.2% Proportion of errors $\leq 8\%$ = 100%					Clause 7.3.1 >90% Class 3 (≤8%)
Up time					99.2%	>95%
Maintenance					30hrs	To be reported

Certificate No: Sira MC170320/01
 This Certificate issued: 17 March 2021

*This certificate may only be reproduced in its entirety and without change
 To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Description

The flowmeter type NF750 including the Correlation Sensor supplied by NIVUS is intended to be used for continuous flow measurement in slight to heavy polluted media with various compositions. The flowmeter can be operated in full pipes. It is a stationary measurement system for flow measurement and storage of the measurement data. The flowmeter simultaneously determines the velocity and level at a common measurement point. The level sensor may contain 2 an air-ultrasonic and hydrostatic level measurement. A piezo crystal with a certain installation angle towards the flow direction operates as a flow velocity sensor. All the particles in the measurement path (air, dirt, suspended solids) reflect a part of the emitted ultrasonic signal pulse. This echo is received by the piezo crystal again and converted to electric signals. After a certain period the echoes of a second pulse are measured too. By correlation these echo the velocity and a velocity profile can be determined. From this velocity profile, hydraulic models are applied (none in the program as newline) to evaluate in each geometry the mean velocity. Associated to the cross section, the discharge is evaluated.

General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of Sira Certificates'. The design of the product certified is defined in the Sira Design Schedule V00 for certificate No. Sira MC170320/00
2. If certified product is found not to comply, Sira Certification Service should be notified immediately at the address shown on this certificate.
3. The Certification Marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of Sira Certificates'.
4. This document remains the property of Sira and shall be returned when requested by the company.

Certificate No: Sira MC170320/01
This Certificate issued: 17 March 2021

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*